

# Sigma Auction

## Heavy Duty Electrical Power Distribution Stations Auction



Large quantity of heavy duty power distribution and electrical equipment from Square D, Schneider Electric, Furnas, and other manufacturers.

424 E Inglefield Rd  
Evansville  
Indiana  
47725  
United States

Ended Dec 16, 2021 12:21pm CT (6:21pm GMT)

Lot	Description
0	Bulk Bid for All Lots in Power Distribution Room 1: These lots include Lot 1 through Lot 18 Subject to Piecemeal Bids - The greater of the aggregate sum of closing bids on Lots 1 through 18 OR the closing bid on the Bulk Lot (Lot 0) will be awarded as the winning bid(s).
1	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 600V Horizontal bus amperes: 600A Short-circuit current rating: 65,000Amps Disconnect switch, ammeter, and push button controls
2	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 600V Horizontal bus amperes: 600A Short-circuit current rating: 65,000Amps Disconnect switch, indicator light, ammeter, and pushbutton controls
3	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 480V Vertical bus amperes: 300A Horizontal bus amperes: 600A Short-circuit current rating: 50,000Amps Array of indicator lights, disconnect switches, selector switches and pushbuttons Furnas 89BFV9270-1 Motor control center: ...[more]
4	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 480V Vertical bus amperes: 300A Horizontal bus amperes: 600A Short-circuit current rating: 50,000Amps Buckets with array of indicator lights, pushbutton controls. and disconnect switches
5	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 480V Vertical bus amperes: 300A Horizontal bus amperes: 600A Short-circuit current rating: 50,000 Amps Three disconnect switches, two ammeters, indicator lights and pushbuttons
6	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 480V Horizontal bus amperes: 600A Vertical bus amperes: 300A Short circuit current rating: 50,000 Amps Buckets with indicator lights, selector switches, and disconnect switches Two Furnas Ammeters
7	Electrical ratings: Phase: 3 Frequency: 50/60 Hertz Max voltage: 600V Horizontal bus ampere: 600 Amps Vertical bus ampere: 600 Amps Short circuit current rating: 65,000 Amps
8	Electrical ratings: Phase: 3 Frequency: 50/60Hz Running indicator light with Ammeter
9	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 480V Indicator light with push button controlled ammeter
10	Running indicator light Ammeter with pushbutton activation
11	Electrical ratings: Max voltage: 600V Phase: 3 Current: 50/60Hz Amperes meter with indicator light
12	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 480V Vertical bus amperes: 300A Horizontal bus amperes: 600A Short-circuit current rating: 50,000Amps Three disconnect switches with two reset pushbuttons Ammeter with pushbutton control

- 13 Electrical ratings: Phase: 3 Frequency: 50/60Hz Max voltage: 480V Horizontal bus amperes: 600A Vertical bus amperes: 300 bus Short circuit current rating: 50,000 Amps Buckers with pushbutton reset and disconnect switches
- 
- 14 Electrical ratings: Phase: 3 Frequency: 50/60Hz Horizontal bus amperes: 600A Vertical bus amperes: 300A Max voltage: 480V Short circuit current rating: 50,000 Amps Buckets with pushbutton reset and disconnect switches
- 
- 15 Electrical: 13.8KV Feeds substation switch units
- 
- 16 Serial: 6PF8858649 Model: Unitrol Electrical requirements: Voltage: 480 Frequency: 60Hz Phase: 3 Wire: 3 Control volts: 120V Vertical bus: 600 Amps Horizontal bus: 1100 Amps Maximum short circuit rating: 50,000 Amps Amperage meter with pushbutton & selector switch controls
- 
- 17 Serial: 6PF8858649 Model: Unitrol Electrical ratings: Voltage: 480V Frequency: 60Hz Phase: 3 Contol volts: 120V Vertical bus: 600Amps Horizontal Bus: 1100Amps Maximum short-circuit rating: 50,000Amps Ammeter with on/off selector switch Motor running indicator light with emergency st ...[more]
- 
- 18 Outfeed: 13.8KV Feeds to capacitor bank B unit switches Viewing window
- 
- 19A Bulk Bid for All Lots in Power Distribution Room 2: These lots include Lot 19 through Lot 32 Subject to Piecemeal Bids - The greater of the aggregate sum of closing bids on Lots 19 through 32 OR the closing bid on the Bulk Lot (Lot 19A) will be awarded as the winning bid(s).
- 
- 19 Electrics: 3 Ph 60 Hz 600 Amps
- 
- 20 Serial: 393201G80. KVA 1000 continuous. Type DGP. % App. IMP. 5.75 at 100 degrees Celsius. Rise 80 degrees Celsius. App. Wt. LBS. 8030. H.V 480v. L.V. 208/120v
- 
- 21 277/480 V 3 Ph 60 Hz 4000 Amps
- 
- 22 Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps QSF Unit: 600 Amps
- 
- 23 Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps
- 
- 24 277/480 V 3 Ph 4000 Amps
- 
- 25 Electrics: 277/480 Volts 3 Ph 60 Hz 4000 Amps
- 
- 26 Electrics: 7960/13800 Volts 3 Ph 60 Hz
- 
- 27 277/480 V 3 Ph 60 Hz 4000 Amps
- 
- 28 Electrics: 277/480 Volts 3 Ph 60 Hz 4000 Amps
- 
- 29 Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps QSF Unit: 600 Amps
- 
- 30 Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps
-

31	Electrics: 277/480 Volts 4000 Amps 3 Ph 60 Hz
32	Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps 2500/3333 KVA 13800 H.V. 104.6/139.5 H.V. Amps 480Y/277 L.V. 3015/4020 V.V. Amps
33A	Bulk Bid for All Lots in Power Distribution Room 3: These lots include Lot 33 through Lot 64 Subject to Piecemeal Bids - The greater of the aggregate sum of closing bids on Lots 33 through 64 OR the closing bid on the Bulk Lot (Lot 33A) will be awarded as the winning bid(s).
33	Motor Control Center Electrics: 460 V 3 Ph 60 Hz 400 HP
34	Electrics: 460 V 3 Ph 60 Hz 400 HP
35	480 V
36	480 V
37	480 V
38	Electrics: 480 V 3 Ph 60 Hz
39	Electrics: 480 V 3 Ph 60 Hz
40	Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps
41	Electrics: 277/480 V 3 Ph 60 Hz
42	Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps
43	Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps
44	Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps. QSF bucket: 600 Amps
45	Electrics: 277/480 V 3 Ph 60 Hz 4000 Amps. QSF bucket: 600 Amps
46	Electrics: 277/480 V 3 Ph 4000 Amps 60 Hz
47	Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps Horizontal 4 wire
48	Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
49	Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
50	Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire QSF Buckets: 240 VAC: 200 max HP 480 VAC: 400 max HP 600 VAC: 500 max HP

- 
- 51 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 52 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 53 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 54 Substation: Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire Transformers: Voltage: 13800 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 2500/3333 KVA
- 
- 55 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 56 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 57 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 58 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire QSF Buckets: 240 VAC: 200 max HP 480 VAC: 400 max HP 600 VAC: 500 max HP
- 
- 59 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire QSF Buckets: 240 VAC: 200 max HP 480 VAC: 400 max HP 600 VAC: 500 max HP
- 
- 60 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 61 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 62 Indoor Wire: 4 Phase: 3 Voltage: 277/480V Section amperes: 4000A Supply amperes: 4000A Section 4 of 9 Five meters of electrical functions Westinghouse digital display unit Power Transformer: Phase: 3 Power: 2500/3333kVA Frequency: 60Hz Voltage: 13,800 delta - 480Y/277 Insulation pro ...[more]
- 
- 63 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 64 Voltage: 277/480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps 4 wire
- 
- 65A Bulk Bid for All Lots in Power Distribution Room 4: These lots include Lot 65 through Lot 76 Subject to Piecemeal Bids - The greater of the aggregate sum of closing bids on Lots 65 through 76 OR the closing bid on the Bulk Lot (Lot 65A) will be awarded as the winning bid(s).
- 
- 65 Square D Power Dry II Sorgel Transformer: Dry-type: Class: AA/FA Type: VPI Phase: 3 IMP: 5.46 Frequency: 60Hz KVA: 2500/333 High Voltage: 13800V kV BIL: 95HV/30LV Low Voltage: 480Y/277 LV amps: 3007/4009A Temperature rise: 80°C Max ambient temperature: 40°C Central Electric Compa ...[more]
- 
- 66 Five meters Westinghouse digital reading display Electrical ratings: Phase: 3 Frequency: 60Hz Voltage: 480V Current: 4,000 Amps Eight Sqaure D QMB Buckets: 3-Poles Phase: 3 Frequency: 60Hz Voltage: 600VAC Current: 600 Amp Horspower range: 150 to 500 HP Disconnect switches
- 
- 67 Nine buckets with Boltswitch pressure contact switches: 3-Pole 3 Wire Current rating: 600 Amps Voltage rating: 600VAC Westinghouse IQ Data Plus II digital display: Displays amps & volts RMS, watts, vars, power factor, demand watts, frequency, and watt-hours Reset button CPC m ...[more]
-

68	Dry-Type Phase: 3 Frequency: 60Hz Power: 2500/3333kVA Class: AA/FA Voltage rating: 480Y/277 HV winding: 95KV LV winding: 30KV Temperature rise: 80°C Amperes vary by connection: 100 to 146Amps
69	Two sections Incoming power: 13.8KV Viewing windows and key-locks
70	Phase: 3 Frequency: 60Hz Max voltage: 600VAC Horizontal bus amperes: 600A One section Touchpad controls with digital display Allen-Bradley BUL-2100 Substations: Phase: 3 Frequency: 60Hz Max voltage: 600VAC Section 1: Vertical bus amperes: 600A Horizontal bus amperes: 600A Sec ...[more]
71	Phase: 3 Frequency: 60Hz Max voltage: 600VAC Section 1: Horizontal bus amperes: 600A Vertical bus amperes: 600A Section 2: Horizontal bus amperes: 600A Vertical bus amperes: 300A Both sections have disconnect switch and indicator light
72	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 600VAC Vertical bus amperes: 300A Horizontal bus amperes: 600A Disconnect switch, indicator light, and stop & start buttons
73	Phase: 3 Frequency: 60 Hz Max voltage: 600VAC Section 1: Vertical bus amperes: 600A Horizontal bus amperes: 600A Section 2: Vertical bus amperes: 300A Horizontal bus amperes: 600A Each section has indicator light, start & stop buttons, and disconnect switches
74	Disconnect switch Allen-Bradley digital touchpad controls
75	Electrical ratings: Phase: 3 Frequency: 60Hz Max voltage: 600V Vertical bus amperes: 300A Horizontal bus amperes: 600A Short-circuit current rating: 65,000Amps Buckets with disconnect switches Two indicator lights and emergency stop buttons
76	Electrical ratings: Phase: 3 Frequency: 60 Hz Max voltage: 600V Vertical bus amperes: 300A Horizontal bus amperes: 600A Short-circuit current rating: 65,000Amps Six disconnect switches Indicator light and emergency stop button
77A	Bulk Bid for All Lots in Power Distribution Room 5: These lots include Lot 77 through Lot 85 Subject to Piecemeal Bids - The greater of the aggregate sum of closing bids on Lots 77 through 85 OR the closing bid on the Bulk Lot (Lot 77A) will be awarded as the winning bid(s).
77	Rated max voltage: 15 kV Impulse withstand (BIL): 95 kV Norm. freq withstand: 36 kV Frequency: 60 hertz Continuous current: 600 A sym Load Interrupting current: 600 A sym Momentary current: 40 kA sym Short time current: kA sym time: 2 sec Fault closing current: 40 kA asym
78	Voltage: 460 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 1030 amps Enclosure type: 12 Field wiring: Cu 75 DEG C Short circuit current rating: 100KA RMS symmetrical 480 VAC max
79	Voltage: 460 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 1030 amps Enclosure type: 12 Field wiring: Cu 75 DEG C Short circuit current rating: 100KA RMS symmetrical 480 VAC max
80	Voltage: 460 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 1030 amps Enclosure type: 12 Field wiring: Cu 75 DEG C Short circuit current rating: 100KA RMS symmetrical 480 VAC max
81	Voltage: 460 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 1030 amps Enclosure type: 12 Field wiring: Cu 75 DEG C Short circuit current rating: 100KA RMS symmetrical 480 VAC max
82	Voltage: 480/277 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 4000 amps Supply bus rating: 4000 amps Section bus rating: 4000 amps Neutral bus rating: 4000 amps Phase: 3PH, 4W System short circuit current rating: 85kA Main bus short circuit current rating: 85kA 8 Schneider Electric bu ...[more]

83	Voltage: 460 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 27 amps
84	Voltage: 600 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 400 amps
85	Voltage: 480/240-240/120 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 52/104-104/208 amps
86A	Bulk Bid for All Lots in Power Distribution Room 6: These lots include Lot 86 through Lot 101 Subject to Piecemeal Bids - The greater of the aggregate sum of closing bids on Lots 86 through 101 OR the closing bid on the Bulk Lot (Lot 86A) will be awarded as the winning bid(s).
86	Voltage: 600 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 65K Amperes
87	Voltage: 480 volts Electrical Phase: 3Ph Hertz: 60Hz 60 KVAR Equipped with internal discharge device
88	Voltage: 480 volts Electrical Phase: 3Ph Hertz: 60Hz 60 KVAR Equipped with internal discharge device
89	13.8 KV CPC Substations Breaker control statons
90	13.8 KV CPC Substations Breaker control statons
91	Voltage: 14480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 132.8 amps HV Winding 95KV Temp rise: 80 Celsius Voltage rating: 13800 Delta-480Y/277 Total weight: 13000 lbs. Insulation class: 220 degrees Celsius
92	Masterpact NW 40 H 240V-100kA 480V-100kA 600V-85kA
93	Masterpact NW 40 H 240V-100kA 480V-100kA 600V-85kA
94	Voltage: 14480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 132.8 amps HV Winding 95KV Temp rise: 80 Celsius Voltage rating: 13800 Delta-480Y/277 Total weight: 13000 lbs. Insulation class: 220 degrees Celsius
95	Voltage: 14480 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 132.8 amps HV Winding 95KV Temp rise: 80 Celsius Voltage rating: 13800 Delta-480Y/277 Total weight: 13000 lbs. Insulation class: 220 degrees Celsius
96	Masterpact NW 40 H 240V-100kA 480V-100kA 600V-85kA
97	Manufacturer: Controlled Power Corporation Serial: 085043281006 Masterpact NW 40 H 240V-100kA 480V-100kA 600V-85kA
98	Manufacturer: Magnetics Serial: T-2104-2 Model: HVT Voltage: 1440 volts Electrical Phase: 3Ph Hertz: 60Hz Amperage: 132.8 amps HV Winding 95KV Temp rise: 80 Celsius Voltage rating: 13800 Delta-480Y/277 Total weight: 13000 lbs. Insulation class: 220 degrees Celsius
99	Lot is for bus bar and ductwork only. Approximate Weight 1000 Pounds
100	Lot is for bus bar and ductwork only. Approximately 1000 pounds
101	Lot is for bus bar and ductwork only. Approximately 1000 pounds

